

R.S.

Yadav & Associates

Mob. : 9810725241
9213534855**R.S. Yadav & Associates**
ENGINEERS, ARCHITECTS & VALUERSGovt. Approved Valuers for
Income Tax, Wealth Tax, Bank Purpose etc.

E-mail : rsyadavengineer@gmail.com

10.07.2020

Dated

Ref. No.

STRUCTURAL STABILITY CERTIFICATE

Property Address : Green Field Public School, situated at GTB Enclave,
Delhi-110093

Name of Owner : Green Field Public School Society **Plot Area**
: 150 Mtrs. X 100 Mtrs. = 15000 Sq. Mtrs.

Built up Area (Sq. Mtrs.) : GF- 2249 Sq. Mtrs., FF- 2249 Sq. Mtrs.,
SF- 2249 Sq. Mtrs., TF- 2249 Sq. Mtrs.

Type of Building : School building

No. of Blocks : 1 block with expansion joints in between.

Year of Construction : 1990

No. of Storey : Ground + 3 floor


Height of Building : Less than 15 meter

I have inspected the above cited school building visually on 8.07.2020 on the request of representative of the society. As per information and details furnished by the owner, the building has been constructed in the year 1990. The existing building consists of ground floor + 3 floors with RCC framed structure/ masonry load bearing walls.

The Building having marble chips/ kota stone flooring and the wall plastered internal as well as external. The physical conditions of the existing building/ structure is good. During the inspection I had not found any cracks, buckling and deflection in columns, beams & slabs and deterioration in the building.

This is certified that the structural parts of the building on the plot belonging to Green Field Public School Society have been designed on the basis of calculations in accordance with the permissible stresses and slenderness ratio as per National Building Code/prevailing BIS Code for structural safety. The above mentioned existing building satisfies the requirements of structural safety from natural hazards including earthquake/ seismic impact.

In my view the above said building is safe and sound at present.



M-9810725241, 9213534855

Er. R.S. YADAV

Regd. Civil Engineer Lic. No. E-1945/2014

Regd. Structure Engineer Lic. No. SE/0179

Member of Institute of Valuer

Office : Chamber No. 61, Typist Block, Civil Side, Tis Hazari Courts, Delhi - 110054

Resi. : B-1233, Street No. 35, Main 25 Feet Road, Sant Nagar, Burari, Delhi-110084

Associates : **SURESH KUMAR, FIE, FIV**
EX. DY. CHIEF ENG. (CIVIL) PSEB
REGD. VALUER (I/589/163/2009-10)
RAJENDER KUMAR
DRAFTMAN